
December 12, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**5BQAQC
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824134	BHSB	2016-12-05 @ 8:00 am	2016-12-08 @ 10:00 am	< 0.3	2016-12-09
7824137	BMSB	2016-12-05 @ 8:00 am	2016-12-08 @ 10:00 am	< 0.3	2016-12-09
7824133	FAB	2016-12-05 @ 8:00 am	2016-12-08 @ 10:00 am	< 0.3	2016-12-09
7824136	JESB	2016-12-05 @ 8:00 am	2016-12-08 @ 10:00 am	< 0.3	2016-12-09
7824135	RESB	2016-12-05 @ 8:00 am	2016-12-08 @ 10:00 am	< 0.3	2016-12-09

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

December 12, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**BHS
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824108	A. DIR.	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	3.4 ± 0.3	2016-12-09
7824109	A. DIR.	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	3.0 ± 0.3	2016-12-09
7824110	CAFé	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	0.6 ± 0.2	2016-12-09
7824112	CR104	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	< 0.3	2016-12-09
7824114	CR201	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	< 0.3	2016-12-09
7824115	CR228	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	1.8 ± 0.2	2016-12-09
7824116	CR228	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	2.1 ± 0.2	2016-12-09
7824111	IT	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	0.7 ± 0.2	2016-12-09
7824113	MO	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	1.1 ± 0.2	2016-12-09

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

December 12, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**BMS
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824128	CR135	2016-12-05 @ 9:00 am	2016-12-08 @ 12:00 pm	1.6 ± 0.2	2016-12-09
7824132	CR171	2016-12-05 @ 9:00 am	2016-12-08 @ 12:00 pm	2.0 ± 0.2	2016-12-09
7824131	CR185	2016-12-05 @ 9:00 am	2016-12-08 @ 12:00 pm	2.6 ± 0.2	2016-12-09
7824129	GYM OFF	2016-12-05 @ 9:00 am	2016-12-08 @ 12:00 pm	1.0 ± 0.2	2016-12-09
7824126	MO	2016-12-05 @ 9:00 am	2016-12-08 @ 12:00 pm	1.5 ± 0.2	2016-12-09
7824127	MO	2016-12-05 @ 9:00 am	2016-12-08 @ 12:00 pm	0.9 ± 0.2	2016-12-09

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

December 12, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

FA

MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824103	CR16	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	1.2 ± 0.2	2016-12-09
7824106	CR18	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	1.1 ± 0.2	2016-12-09
7824107	CR24	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	0.7 ± 0.2	2016-12-09
7824104	CR4	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	1.1 ± 0.2	2016-12-09
7824105	MEDIA	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	0.7 ± 0.2	2016-12-09
7824102	MO	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	0.7 ± 0.2	2016-12-09
7824101	MO	2016-12-05 @ 7:00 am	2016-12-08 @ 10:00 am	0.8 ± 0.2	2016-12-09

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

December 12, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**JES
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824125	BAND	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	< 0.3	2016-12-09
7824123	CR13	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	0.7 ± 0.2	2016-12-09
7824124	CR4	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	1.0 ± 0.2	2016-12-09
7824121	MO	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	0.6 ± 0.2	2016-12-09
7824122	MO	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	< 0.3	2016-12-09

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

December 12, 2016

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**RES
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7824120	CAFé	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	0.7 ± 0.2	2016-12-09
7824119	CR103	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	< 0.3	2016-12-09
7824118	MO	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	0.5 ± 0.2	2016-12-09
7824117	MO	2016-12-05 @ 8:00 am	2016-12-08 @ 11:00 am	< 0.3	2016-12-09

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498